



October 14, 2020

To: Prospective Bidders, and Plan Holders

From: Westmoreland County, Resource International and HDH Associates

**ADDENDUM # 3  
RESCUE SQUAD - ADDITION  
OAK GROVE, VIRGINIA  
WESTMORELAND COUNTY**

**CHANGES AND CLARIFICATION – GENERAL**

- Please note: All work is required to be complete by Dec 30, 2020. All funding withdrawn at that point. Owner acknowledges aggressive schedule and is aware of COVID delayed deliveries.
- Existing windows are from West Window Corp located in Martinsville VA
  - Phone number 276/638-2394.
  - The window was constructed from T6063-T6 aluminum with poured urethane thermal break.
- At this time the only permit expected is the building permit, contractor to obtain
- P-1 is floor drain (per specifications Zurn, Model ZN-414 or equal)
- P-2 is yard hydrant (per specifications Zurn, Model Z-1395 or equal)
- Per Addendum # 1 "Sheet A2; East Elevation – Additive Bid Roof is intended to be shingles"
- Per Addendum # 1 "Sheet A2; North Elevation shows outline of doors, the intent is to include all 4 overhead door"
- Per Addendum # 1 "Site work included is only that as shown on drawings Sheets G1 & G2, C1 thru C5.
- Washer drain pan - Killarney Metals or equal
- Owner does not have extra flooring material in stock, contractor to match existing
- Attached existing building design drawing S-1
- Attached existing site design drawing C-2

**Changes and Clarifications to Specifications**

- None

**Changes and Clarifications to Drawings**

- None

**ATTACHMENTS:** Existing Building Design Drawing S-1 (1)  
Existing Site Design Drawing C-2 (1)

**END OF ADDENDUM # 3**



